

Standards of Training in Gas Work

Gas Skills Training and Assessment

Information Sheet	IMPORTANT - This course was formerly known as <u>ACOPS</u>
Title	STGW 170 LPG Safety Bulk Storage Routine Inspection
Duration	1 day
Aims and Objectives	The course provides the knowledge required to identify potential hazards associated with LPG installations. We provide guidance to those involved with fixed bulk storage of LPG at customer's premises. We discuss the requirements for carrying out the routine inspection of vessels and equipment, having a capacity greater than 150 litres and less than 5000 litres. Items which are included in a supplier's written scheme and operating at a pressure in excess of 0.5 bar.
Scope	The programme is intended for workers that are required to routinely inspect bulk LPG installations, such as LPG delivery drivers.
Pre-Requisites	Candidates must have completed a basic health and safety course and be familiar with bulk LPG installations.
Training	<p>The training programme will utilise our Book 6 An Introduction to LPG handbook. The following training topics will be covered:</p> <ul style="list-style-type: none">• Purpose of inspections• Site environment• Condition of vessel(s)• Storage compounds• Warning notices• Record keeping• Reporting requirements
Competence	The candidate's knowledge and understanding of the subject will be established by the application of a multi-choice question paper.
Assessment	There will be a short knowledge and understanding test upon completion of the course. The assessment will be conducted by an assessor qualified to A1 or equivalent standard.
Verification	The assessment process will be verified by an internal verifier qualified to V1 or equivalent standard.
Certification	<p>The programme will be certificated by LPG Training. A certificate of attendance will be issued to successful candidates. Photo ID cards are available at extra cost.</p> <p>Alternatively we can arrange certification through Logic Certification Ltd – A Certification Body accredited by UKAS as compliant with the requirements of BS EN ISO 17024. Please inform us of this preference at the time of order as this will involve additional time and cost.</p>